

DISTRICT WATER TESTING LABORATORY, MANSA
Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa
dwtlmansa@gmail.com

To,

Silver Bells International School, Behniwal
Vill. Behniwal , District Mansa

No.: DWTL/MNS/2324/00003 Dated : 18/04/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. SBIS-9-2023 Dated: 01/04/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 05/04/2023. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Mansa

D/A : Test Report

Komal Sharma

Authorized Signatory
For, District Water Testing Laboratory, Mansa

Salinder Singh

President
Silver Educational Welfare Society (Regd.)
Behniwal (Mansa) (Pb.)

Indira 3/5/23

Principal
Silver Bells International School (Secondary)
BEHNIWAL (Mansa)

DISTRICT WATER TESTING LABORATORY, MANSA

Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa
dwtlmansa@gmail.com

TEST REPORT			
Name & Address of Customer : Silver Bells International School, Behniwal Vill. Behniwal , District Mansa		Customer Reference No.	No : SBIS-9-2023 Date : 01/04/2023
		Sample Submitted by	Balvinder Singh
		Date of Sample Receipt	05/04/2023
		Analysis Starting Date	05/04/2023
		Analysis completion Date	06/04/2023
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC000123000000058F	Sample Type :	Water
Test Report No.:	DWTL/MNS/2324/00003	Date of Issue :	18/04/2023
Registration no.:	DWTL/MNS/REG2324/00003	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	500 ml / Transparent Plastic Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Silver Bells International School, Behniwal / NA
Village :	Behniwal	Habitation :	Behniwal
Block:	Jhunir	District :	Mansa
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Colour	4	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
2	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
3	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
4	TDS	190	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Alkalinity	56	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
6	Hardness	20	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
7	Calcium	5	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
8	Magnesium	2	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
9	Chloride	26	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Komal Sharma

Ms. Komal Sharma
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory, Mansa

Salwinder Singh
President
Silver Educational Welfare Society (Regd.)
Behniwal (Mansa) (Pb.)

End of the Test Report

Principal
Silver Bells International School (Secondary)
BEHNIWAL (Mansa)

Indu
3/5/23